

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave.St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:**Pursell, Gary**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-015087**Date Inspected:** 20-Jun-2010**Project Name:** SAS Superstructure**OSM Arrival Time:** 700**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1900**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China

CWI Name:	Mr. Xu Le Feng/ Mr. Gao Zhi Ch			CWI Present:	Yes	No	
Inspected CWI report:	Yes	No	N/A	Rod Oven in Use:	Yes	No	N/A
Electrode to specification:	Yes	No	N/A	Weld Procedures Followed:	Yes	No	N/A
Qualified Welders:	Yes	No	N/A	Verified Joint Fit-up:	Yes	No	N/A
Approved Drawings:	Yes	No	N/A	Approved WPS:	Yes	No	N/A
				Delayed / Cancelled:	Yes	No	N/A
Bridge No:	34-0006			Component:	Tower		

Summary of Items Observed:

On this date Caltrans OSM Quality Assurance(QA) Inspector, Baskar Govindarajan, was present during the times noted above for observations relative to the work being performed.

Bay no. 11

1.This QA inspector, Baskar Govindarajan, observed, ZPMC qualified welding personnel identified as 202100 perform SMAW Buttering welding on; Lift 5, Transverse diaphragm plate and the weld joint is identified as LD5-4. ZPMC CWI Identified as Mr. Yu Dong Ping. The welding parameters as measured using QC's calibrated instruments appeared to be in general compliance with WPS-485-SMAW-2G (2F)-Repair. CWR Report no. for the same found to be T-CWR-637. (Photo attached)

2.This QA inspector, Baskar Govindarajan, observed, ZPMC qualified welding personnel identified as 044541 perform SMAW Repair welding on; Spare strut Flange to stiffener and the weld joint is identified as ED1-STSA4-10-119mtr.-2-8A/B. ZPMC CWI Identified as Mr. Yu Dong Ping. The welding parameters as measured using QC's calibrated instruments appeared to be in general compliance with WPS-485-SMAW-2G (2F)-FCM-Repair-1. (Photo attached)

3.This QA inspector, Baskar Govindarajan, observed, ZPMC qualified welding personnel identified as 202100 perform SMAW welding on; West Shaft, Lift 5 Transverse diaphragm plate on Skin A and the weld joint is identified as WSD1-TL5-4 B/F-11B. ZPMC CWI Identified as Mr. Xu Le Feng. The welding parameters as measured using QC's calibrated instruments appeared to be in general compliance with WPS-B-T-3213-B-U3B.

WELDING INSPECTION REPORT

(Continued Page 2 of 3)

Bay no. 10

4.This QA inspector, Baskar Govindarajan, observed, ZPMC qualified welding personnel identified as 053049 perform SMAW Repair welding on; Lift 4 to 5, interior splice plate and the weld joint is identified as SSD1-SPSA5-19. ZPMC CWI Identified as Mr. Gao Zhi Chun. The welding parameters as measured using QC's calibrated instruments appeared to be in general compliance with WPS-485-SMAW-2G (2F)-Repair.

5.This QA inspector, Baskar Govindarajan, observed, ZPMC qualified welding personnel identified as 050289 perform SMAW welding on; Lift 4 to 5, interior splice plate and the weld joint is identified as NSD1-SPSA5-6-4B. ZPMC CWI Identified as Mr. Gao Zhi Chun. The welding parameters as measured using QC's calibrated instruments appeared to be in general compliance with WPS-B-T-3211-TC-U5B-1.

6.This QA inspector, Baskar Govindarajan, observed, ZPMC qualified welding personnel identified as 052930/ 052493 perform SMAW welding on; North Shaft, Lift 5 Transverse diaphragm plate on Skin A and the weld joint is identified as ND1-TL5-3 B/F-24B, 41A. ZPMC CWI Identified as Mr. Gao Zhi Chun. The welding parameters as measured using QC's calibrated instruments appeared to be in general compliance with WPS-B-T-3213-B-U3B.

Unless otherwise noted, all work observed on this date appeared to be in general compliance with the applicable contract documents.



Summary of Conversations:

No relevant conversations.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Micheal Ng (15921845703), who represents the Office of Structural Materials for your project.

WELDING INSPECTION REPORT

(Continued Page 3 of 3)

Inspected By:	Baskar,Govindarajan	Quality Assurance Inspector
----------------------	---------------------	-----------------------------

Reviewed By:	Clifford,William	QA Reviewer
---------------------	------------------	-------------
